

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-1373:102

Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** First Alert Professional, 165 Eileen Way, Syosset NY 11791  
Contact: David Kalmus (516) 921-6704

**DESIGN:** Models FA110C, FA120C, FA142C\* and FA145C\* residential fire alarm control units. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as a household control units for use with the following accessories: Model 5706 photoelectric smoke detector (CSFM Listing No. 7272-0078:152), Model 5727 wireless keypad, System Sensor Model PA400B remote signal sounder (CSFM Listing No. 7135-1209:143).

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:** Combined 7167-1373:104 into 7167-1373:102

**XLF:** 7167-0078:157

\*Rev. 04-23-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**